



MOGALAKWENA MUNICIPALITY

RE- ADVERTISEMENT

REQUEST TO SUBMIT QUOTATIONS NOTICE: 172/2013

ELECTRICAL SERVICES

The Mogalakwena Municipality hereby invites service providers to supply and deliver the following items.

SPECIFICATION FOR SUPPLY AND DELIVERY OF S450 METER BOX

ITEM NO.	DESCRIPTION	QUANTITY
1.	<p><u>EXAMPLES OF THE METER BOXES, (4 WAY AND 6 WAY) ARE AVAILABLE AT THE MAIN STORE, 7 RETIEF STREET, MOKOPANE</u></p> <p>THE ENCLOSURES ARE OF THE FREE STANDING TYPE SUITABLE FOR HOUSING ELECTRICAL EQUIPMENT AND THE TERMINATION OF ELECTRICAL CABLES.</p> <p>THESE SHALL BE MANUFACTURED FROM GLASSFIBRE REINFORCED CEMENT USING SUITABLE ALKALI RESISTANT GLASS FIBRE AND INCORPORATING A GALVANISED MESH REINFORCING GRID IN THE COMPONENT PARTS. THE ENCLOSURE SHALL BE OF THE BOLT TOGETHER TYPE WITH A BASE, 2 SIDE PANELS, A ROOF AND TWO LOWER SLIDE PANELS.</p> <p>THE PARTS SHOULD BE INTERCHANGABLE IN ORDER TO REPLACE PARTS THAT MAY BECOME DAMAGED IN SERVICE. 3CR12 POWDERCOATED HINGED DOORS MUST BE PROVIDED. THE SIDE PANELS SHALL HAVE AN INTERNAL BLOCK PATTERN TO ALLOW THE BOARDS AND CABLE TERMINATION ASSEMBLY TO BE MOVED FORWARDS, BACKWARDS, UP OR DOWN AS REQUIRED. THE KIOSK MUST BE ABLE TO BE BURIED INTO THE GROUND OR STAND INDEPENDANTLY WITHOUT HAVING TO BUILD A SEPARATE PLINTH.</p>	30

<p>A FIBREGLASS NON CONDUCTIVE EQUIPMENT BOARD SHALL BE PROVIDED PREDRILLED FOR THE REQUIRED NUMBER OF CIRCUIT BREAKERS AND KWH METERS. THE CIRCUIT BREAKERS SHOULD BE MOUNTED AT THE TOP OF THE BOARD WITH THE METERS BELOW THAT. THE FSM450 IS A 4 CONSUMER KIOSK WHILE THE FSM700 IS A 6 CONSUMER KIOSK.</p> <p>PROVISION SHOULD BE MADE FOR EACH CONSUMER TO RECEIVE SINGLE OR THREE PHASE POWER. ADDITIONALLY WINDOWS MUST BE MACHINE PUNCHED IN THE FRONT DOOR AND FITTED WITH 3MM POLYCARBONATE UV RESISTANT WINDOWS. THESE MUST BE POP RIVITED TO THE DOORS AND FURTHER SEALED WITH SILICONE SEALER. THE WINDOWS MUST MATCH THE PREDRILLED MOUNTING HOLES FOR THE TP KWH METERS.</p> <p>A SET OF COPPER BUSBARS FOR THREE PHASES AND NEUTRAL MUST BE PROVIDED. THESE SHOULD BE A MINIMUM OF 25X 6.3MM X250MM LONG HORIZONTALLY MOUNTED ON COLOUR CODED STANDOFF INSULATORS. EACH BAR MUST HAVE SUFFICIENT HOLES FOR AN INCOMING AND AN OUTGOING LARGER CABLE AND 1 PER CONSUMER PLUS 1 SPARE. YELLOW PLATED HEX SET SCREWS MUST BE PROVIDED FOR EACH HOLE WITH 2 FLAT WASHERS, AN INTERNAL LOCK WASHER AND A NUT EACH.</p> <p>CABLE TERMINATION MUST BE VIA SUITABLY SIZED STAINLESS STEEL PIPES EACH WELDED WITH A STAINLESS STEEL STUD AND FIXED THROUGH BACK TO BACK P4000 UNISTRUT. THE PIPES SHOULD EACH HAVE A STAINLESS STEEL HOSE CLAMP. A LARGE EARTH STUD SHOULD ALSO BE ATTACHED THROUGH THE UNISTRUT.</p>	
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--

The following conditions shall apply:

- Errors and/or omissions in technical specification of the offer, or the price calculations will disqualify your bid.
- Quotations in sealed envelope written the notice number and/or description of service must be deposited in the Tender box to the Supply Chain Management Unit at 07 Retief street Mokopane (Cnr of Fourie and Retief Street - STORES BUILDING) between 07h30-16h30 (excluding between 13h00-14h00)
- No pricing option is allowed. Only one price for one brand must be supplied.
- Please indicate the brand which is quoted and that which will be delivered.
- All goods supplied must be SABS approved.
- All awards are subject to the user division confirming the sample.
- Only firm prices will be accepted, non-firm prices (including prices subject to rates of exchange variations) will not be considered.
- Closing date for submissions will be **Thursday 30th January 2014 at 12h00.**
- Quotations must be accompanied by:
 1. valid Tax clearance certificate;
 2. CK/Company registration certificate,
 3. B-BBEE status level certificate from an accredited agency, auditors or accountants,
 4. MBD 1, MBD 4, MBD 6.1 and MBD 8 forms obtainable on the Municipal website www.mogalakwena.gov.za and procurement office (stores)
- Fixed prices must be valid for thirty (30) days.

- VAT MUST BE LEVIED BY VAT REGISTERED SUPPLIERS ONLY.
- Suppliers must be in a position to deliver within 14 days upon receipt of official order.

Quotations will be evaluated on a 80/20 point system. Whereas 80 points will be for price and 20 for preference as per PPPFA 2000, BBBEEA 2003 and preferential procurement regulations 2011. *(More information about application and requirements, please refer to MBD 6.1 for compliance and guidance on how to be accredited or to be verified)*

For further enquiries, please contact Mr. Johan Fourie in the Electrical department at 015 491 9648.

KEKANA S.W
MUNICIPAL MANAGER

54 Retief street
Mokopane 0600