



MOGALAKWENA MUNICIPALITY

RE-ADVERTISEMENT

ADVERT DATE: 09 JANUARY 2015
CLOSING DATE: 20 JANUARY 2015
CLOSING TIME: 12H00

REQUEST TO SUBMIT QUOTATIONS NOTICE: 264/2014

CORPORATE SUPPORT SERVICES

The Mogalakwena Municipality hereby invites service provider to supply and deliver the following items.

SPECIFICATION FOR MOGALAKWENA MUNICIPALITY EMERGENCY EVACUATION SYSTEM

PURPOSE

To enable employees, clients, visitors, contractors etc to effectively respond to any emergency that might require evacuation of the premises.

COMPONENTS OF THE SYSTEM SHOULD INCLUDE:

Public address and Voice Alarm

- INPUTS (Fire mic; Fire Alarm; Paging mic; Voice alarm)
 - AMPLIFIERS
 - NOISE SENSING
1. **INITIATING DEVICES**- To activate fire alarm when the smoke detector goes off or the fire alarm panic button is activated.
 2. **NOTIFICATION DEVICES**-To allow effective communication by the speaker through the mic and announcement.

3. **TO BE DIVIDED INTO COLOR CODED ZONE**-To ensure proper monitoring and to allow identification of specific location during emergency.
4. **FAULT MONITORING DEVICE**-To indicate fault or errors within the layout diagram of the system. E.g. Stand-by power supply.
5. **TROUBLE SHOOTING**(FAULTS REPORTING)
6. **MAPPING LAYOUT**- That provides a layout diagram clearly identifying the entire system in zones.
7. **BATTERY BACK-UP**
8. **FIRE INTERFACE**-(INITIATING DEVICE)
9. **EMERGENCY BOARD INDICATOR WITH COLOR CODED SIGNALS**
 - 9.1 ACTIVATED SMOKE DETECTOR
 - 9.2 ACTIVATED FIRE ALARM
 - 9.3 AFFECTED ZONE AREA

MAIN BUILDING (Civic Centre):

156 Room Speakers

156 Smoke Detectors

4 Horn Speakers (**To be mounted outside the building**)

Cabinet Speaker in the Passage

- 2nd Floor at least 3 Speaker
- 1st Floor at least 6 Speaker
- Ground Floor at least 4 Speaker

FIRE ALARM-

GROUND FLOOR EAST- at least **3**

GROUND FLOOR WEST- at least **3**

FIRST FLOOR-EAST- at least **4**

FIRST FLOOR-WEST- at least **2**

SECOND FLOOR- at least **3**

LLEKA LEKALAKALA BUILDING

- 47 Room Speaker
- 6 Room speaker in the Passage
- 35 Smoke detector

CLINIC BUILDING

- 21 Room Speaker
- 3 Room Speaker in the Passage
- 24 Smoke detector

NETWORK LAYOUT ARRANGEMENT:

NB: The network layout arrangement must link the buildings:

1. Main Building
2. Lleka Lekalakala
3. Clinic Building

4. Fire Station

THE SYSTEM MUST ALLOW/ CATER FOR FUTURE ADD-ONS

NB: ALL BIDDERS ARE INVITED TO ATTEND A COMPULSORY BRIEFING SESSION

DATE: 15 JANUARY 2015

VENUE: 54 RETIEF STREET IN OLD COUNCIL CHAMBER

TIME:10:00.

The following conditions shall apply:

- Sealed quotations in sealed envelope written the notice number and/or description of service must be deposited in the Tender box to the Supply Chain Management Unit at 07 Retief street Mokopane (Cnr. of Fourie and Retief Street - STORES BUILDING) between 07h30-16h30 (excluding between 13h00-14h00)
- Quotations must be accompanied by:
 -
 - 1. valid Tax clearance certificate;
 - 2. CK/Company registration certificate,
 - 3. B-BBEE status level certificate from an accredited agency, auditors or accountants,
 - 4. MBD 1, MBD 4, MBD 6.1, MBD 6.2 and MBD 8 and MBD 9 forms obtainable on the Municipal website www.mogalakwena.gov.za and procurement office (stores)
- Quotation which are submitted in the **wrong tender box, faxed, e-mailed and submitted after the closing time** will not be considered.
- Errors and/or omissions in technical specification of the offer, or the price calculations will disqualify your bid
- No pricing option is allowed. Only one price for one brand must be supplied.
- Please indicate the brand which is quoted and that which will be delivered.
- Only locally produced or locally manufactured textiles, clothing, leather and footwear from local, raw material or input will be considered.
- The exchange rate to be used for the calculation of local production and content must be the exchange rate published by the South African Reserve Bank (SARB) at 12:00 on the date of advertisement of the bid.
- SABS approved technical specification number SATS 1286:2011 will be used to calculate local content.
- All awards are subject to the user division confirming the sample.
- Only firm prices will be accepted, non-firm prices (including prices subject to rates of exchange variations) will not be considered.
- Fixed prices must be valid for thirty (30) days.
- VAT MUST BE LEVIED BY VAT REGISTERED SUPPLIERS ONLY.

- Suppliers must be in a position to deliver within 14 days upon receipt of official order.

Quotations will be evaluated on a 80/20 point system. Whereas 80 points will be for price and 20 for preference as per PPPFA 2000, BBBEEA 2003 and preferential procurement regulations 2011. *(More information about application and requirements, please refer to MBD 6.1 for compliance and guidance on how to be accredited or to be verified)*

For technical enquiries, please contact Ms. Naomi Magale in the Corporate support services at 015 491 9805 and for administrative enquiries please contact Ms. Moyahabo Rasekgala in the SCM division at 015 491 9662.

Selepe PP
Acting Municipal Manager
54 Retief street
Mokopane
0600